

TELECOM CABLE-INSTRUMENTATION CABLE

Cable Description:

Conductor:

0.5mm² (7/0.30mm); 1.0mm² (14/0.30mm) and 1.5mm² (19/0.30mm) plain annealed copper wire in accordance with SANS 1411, Part 1 class 2

Insulation:

Cross linked polyethylene (XLPE) compound in accordance with SANS 1411, Part 4

Core Identification:

Black and white insulated cores; numbered alpha and numerically, at regular intervals

Individual and / or overall screen:

Overall screen: Aluminium/polyester tape with a 7/0.30mm 0.50mm² sized tinned annealed copper drain wire

Bedding sheath:

Polyvinyl chloride (PVC) compound in accordance with SANS 1411, Part 2 type B1. The standard bedding sheath colour is black

Final sheath and / or armouring:

Aluminium polyethylene laminated (APL) tape over a 7/0.30mm 0.50mm² sized tinned annealed copper drain wire.

Polyethylene (PE) compound in accordance with SANS 1411, Part 7, type P54. The standard outer sheath colour is black


Multi-pair; 0.5, 1.0, 1.5mm² conductor sizes, XLPE Insulation, overall screened, PVC bedding, APL armour, Polyethylene outer sheath

General Data:

Typical Applications:

Used For Transmission of analogue and digital signals in instrumentation and control systems, not allowed for direct connection to low impedance sources, e.g. public mains electricity supply

Recommended For Indoor and outdoor installations on racks, trays, or conduits, in dry or wet locations; not for direct burial



TELECOM CABLE-INSTRUMENTATION CABLE

Product Information:

Electrical Characteristics		0.5mm ²	1.0mm ²	1.5mm ²
Conductor resistance at 20 °C	(max Ω/km)	39.6	19.5	14.4
Insulation resistance at 20 °C	(min GΩ/km)	5	5	5
Core to core capacitance at 20 °C	< 4 pair cable (nom nF/km)	95	115	130
	> 4 pair cable (nom nF/km)	60	75	80
Core to screen capacitance at 20 °C	< 4 pair cable (nom nF/km)	190	230	260
	> 4 pair cable (nom nF/km)	120	150	160
Inductance	(nom mH/km)	0.72	0.64	0.63
Test Voltage (kV DC)	Core to core	1.5	1.5	1.5
	Core to screen	1.0	1.0	1.0
Operating Voltage	(max V)	300	300	300
Physical Characteristics				
Operating Temperature (max)	(°C)	90	90	90
Fire Retardancy		n/a	n/a	n/a
Bending Radius (min)	(mm)	9 x overall cable diameter		

TELECOM CABLE-INSTRUMENTATION CABLE

Product Description	Bedding	Overall	Cable	Standard
	Diameter	Diameter	Weight	Drum
	under APL (mm)	(mm)	(kg / 1000m)	(Length / m)
1 Pair 0.5mm ² XLPE OAM PVC APL/PE	5.2	8.8	87	1000
2 Pair 0.5mm ² XLPE OAM PVC APL/PE	7.3	10.8	114	1000
4 Pair 0.5mm ² XLPE OAM PVC APL/PE	9.2	12.7	159	1000
8 Pair 0.5mm ² XLPE OAM PVC APL/PE	12.0	15.4	244	1000
12 Pair 0.5mm ² XLPE OAM PVC APL/PE	15.0	18.9	345	1000
16 Pair 0.5mm ² XLPE OAM PVC APL/PE	16.3	20.2	409	1000
24 Pair 0.5mm ² XLPE OAM PVC APL/PE	19.6	23.5	553	1000
1 Pair 1.0mm ² XLPE OAM PVC APL/PE	6.5	10	105	1000
2 Pair 1.0mm ² XLPE OAM PVC APL/PE	8.5	12	148	1000
4 Pair 1.0mm ² XLPE OAM PVC APL/PE	11.3	14.8	235	1000
8 Pair 1.0mm ² XLPE OAM PVC APL/PE	14.2	18.1	369	1000
12 Pair 1.0mm ² XLPE OAM PVC APL/PE	18.0	21.9	505	1000
16 Pair 1.0mm ² XLPE OAM PVC APL/PE	20.0	24.3	632	1000
24 Pair 1.0mm ² XLPE OAM PVC APL/PE	24.1	28.4	885	1000
1 Pair 1.5mm ² XLPE OAM PVC APL/PE	7.0	10.9	123	1000
2 Pair 1.5mm ² XLPE OAM PVC APL/PE	9.3	12.2	175	1000
4 Pair 1.5mm ² XLPE OAM PVC APL/PE	12.4	16.3	279	1000
8 Pair 1.5mm ² XLPE OAM PVC APL/PE	16.0	19.3	448	1000
12 Pair 1.5mm ² XLPE OAM PVC APL/PE	19.8	23.4	611	1000
16 Pair 1.5mm ² XLPE OAM PVC APL/PE	22.4	26.1	796	1000
24 Pair 1.5mm ² XLPE OAM PVC APL/PE	27.1	30.8	1120	1000

Complete your Project:

Please select the items you require and we will be in touch

Cables and Wires:

Indoor
Outdoor
General
Other
Let an ACTOM
Specialist Contact you

Lighting:

Indoor
Outdoor
General
Other
Let an ACTOM
Specialist Contact you

Transformers (Distribution):

Indoor
Outdoor
General
Other
Let an ACTOM
Specialist Contact you

Accessories:

Indoor
Outdoor
General
Other
Let an ACTOM
Specialist Contact you

Specific Information:

Address: 4 Branch Road, Germiston 1401, P.O. Box 678, Germiston 1400

For more Information on this Product Please Send us the Following

Product Information:

Product Name:

Quantity:

Project Name:

Date the Product is required:

Your Contact Information:

Name and Surname:

Company:

Email:

Phone Number:

Province:

Thank You

For having a Look at this Product

Please send this PDF back to us with all your Information

Scan the QR Code to visit our Website:

